

June 25, 2021

Ken Smith  
Holland Patent Central School District  
9601 Main Street  
Holland Patent, NY 13354

RE: Project: HOLLAND PATENT MS 5/26  
Pace Project No.: 70176067

Dear Ken Smith:

Enclosed are the analytical results for sample(s) received by the laboratory on June 08, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Lea Sherman  
lea.sherman@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Patricia Cerio, Utica City School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 1		Lab ID: 70176067001	Collected: 05/26/21 05:47	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.8</b>	ug/L	1.0	1		06/25/21 11:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 2		Lab ID: 70176067002	Collected: 05/26/21 05:48	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 11:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 3		Lab ID: 70176067003	Collected: 05/26/21 05:51	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.7</b>	ug/L	1.0	1		06/25/21 11:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 4		Lab ID: 70176067004	Collected: 05/26/21 05:52	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 11:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 5		Lab ID: 70176067005	Collected: 05/26/21 05:53	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		06/25/21 11:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: <b>HPMS 6</b>	Lab ID: <b>70176067006</b>	Collected: 05/26/21 06:06	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.6</b>	ug/L	1.0	1		06/25/21 11:49	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 7		Lab ID: 70176067007	Collected: 05/26/21 06:07	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>22.0</b>	ug/L	1.0	1		06/25/21 11:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 8		Lab ID: 70176067008	Collected: 05/26/21 06:08	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>20.1</b>	ug/L	1.0	1		06/25/21 11:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 9		Lab ID: 70176067009	Collected: 05/26/21 06:09	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>30.8</b>	ug/L	1.0	1		06/25/21 11:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 10		Lab ID: 70176067010	Collected: 05/26/21 05:58	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		06/25/21 11:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 11		Lab ID: 70176067011	Collected: 05/26/21 05:59	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.8</b>	ug/L	1.0	1		06/25/21 11:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 12		Lab ID: 70176067012	Collected: 05/26/21 06:00	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		06/25/21 11:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 13		Lab ID: 70176067013	Collected: 05/26/21 06:02	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>15.0</b>	ug/L	1.0	1		06/25/21 11:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 14		Lab ID: 70176067014	Collected: 05/26/21 06:03	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>19.3</b>	ug/L	1.0	1		06/25/21 12:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 17	Lab ID: 70176067015	Collected: 05/26/21 05:42	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		06/25/21 12:02	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 20		Lab ID: 70176067016		Collected: 05/26/21 05:38	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		06/25/21 12:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 21	Lab ID: 70176067017	Collected: 05/26/21 05:39	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>27.2</b>	ug/L	1.0	1		06/25/21 12:04	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 22		Lab ID: 70176067018	Collected: 05/26/21 05:40	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		06/25/21 12:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 23	Lab ID: 70176067019	Collected: 05/26/21 05:41	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>12.9</b>	ug/L	1.0	1		06/25/21 12:05	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 24		Lab ID: 70176067020	Collected: 05/26/21 05:37	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: <b>HPMS 25</b>	Lab ID: <b>70176067021</b>	Collected: 05/26/21 05:35	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		06/25/21 12:09	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: <b>HPMS 30</b>	Lab ID: <b>70176067022</b>	Collected: 05/26/21 05:31	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		06/25/21 12:14	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 31		Lab ID: 70176067023	Collected: 05/26/21 05:32	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		06/25/21 12:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 32		Lab ID: 70176067024		Collected: 05/26/21 05:33	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		06/25/21 12:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 34	Lab ID: 70176067025	Collected: 05/26/21 05:29	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.0</b>	ug/L	1.0	1		06/25/21 12:17	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 35		Lab ID: 70176067026	Collected: 05/26/21 05:30	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>12.9</b>	ug/L	1.0	1		06/25/21 12:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 36		Lab ID: 70176067027	Collected: 05/26/21 05:17	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 37		Lab ID: 70176067028	Collected: 05/26/21 05:18	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		06/25/21 12:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 38		Lab ID: 70176067029	Collected: 05/26/21 05:19	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.6</b>	ug/L	1.0	1		06/25/21 12:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 40		Lab ID: 70176067030	Collected: 05/26/21 05:21	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 41		Lab ID: 70176067031	Collected: 05/26/21 05:22	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 42		Lab ID: 70176067032	Collected: 05/26/21 05:23	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		06/25/21 12:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 43		Lab ID: 70176067033	Collected: 05/26/21 06:21	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>28.3</b>	ug/L	1.0	1		06/25/21 12:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 44		Lab ID: 70176067034	Collected: 05/26/21 06:22	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>23.1</b>	ug/L	1.0	1		06/25/21 12:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 45		Lab ID: 70176067035		Collected: 05/26/21 06:23	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>64.8</b>	ug/L	1.0	1		06/25/21 12:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 52		Lab ID: 70176067036	Collected: 05/26/21 06:35	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>342</b>	ug/L	1.0	1		06/25/21 12:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 53		Lab ID: 70176067037	Collected: 05/26/21 06:26	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>170</b>	ug/L	1.0	1		06/25/21 12:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 54		Lab ID: 70176067038	Collected: 05/26/21 06:27	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>93.9</b>	ug/L	1.0	1		06/25/21 12:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 55		Lab ID: 70176067039	Collected: 05/26/21 06:28	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>38.9</b>	ug/L	1.0	1		06/25/21 12:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 56		Lab ID: 70176067040	Collected: 05/26/21 06:29	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.4</b>	ug/L	1.0	1		06/25/21 12:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 60		Lab ID: 70176067041	Collected: 05/26/21 06:30	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.7	ug/L	1.0	1		06/25/21 12:40	7439-92-1	M1

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 61		Lab ID: 70176067042	Collected: 05/26/21 06:31	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>41.6</b>	ug/L	1.0	1		06/25/21 12:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 62		Lab ID: 70176067043		Collected: 05/26/21 06:32	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 63		Lab ID: 70176067044		Collected: 05/26/21 06:35	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.5</b>	ug/L	1.0	1		06/25/21 12:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 64		Lab ID: 70176067045		Collected: 05/26/21 06:36	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.7</b>	ug/L	1.0	1		06/25/21 12:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: <b>HPMS 65</b>	Lab ID: <b>70176067046</b>	Collected: 05/26/21 06:37	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>22.5</b>	ug/L	1.0	1		06/25/21 12:48	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 66		Lab ID: 70176067047	Collected: 05/26/21 06:38	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.6</b>	ug/L	1.0	1		06/25/21 12:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 79		Lab ID: 70176067048	Collected: 05/26/21 06:27	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 81		Lab ID: 70176067049	Collected: 05/26/21 06:43	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 85		Lab ID: 70176067050		Collected: 05/26/21 05:25		Received: 06/08/21 10:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/25/21 12:52	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 86		Lab ID: 70176067051	Collected: 05/26/21 05:45	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 87		Lab ID: 70176067052	Collected: 05/26/21 05:46	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 12:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 88		Lab ID: 70176067053	Collected: 05/26/21 05:58	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		06/25/21 12:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 89		Lab ID: 70176067054	Collected: 05/26/21 05:55	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 13:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 90		Lab ID: 70176067055	Collected: 05/26/21 06:13	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.1</b>	ug/L	1.0	1		06/25/21 13:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 91		Lab ID: 70176067056	Collected: 05/26/21 06:14	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>18.0</b>	ug/L	1.0	1		06/25/21 13:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 92		Lab ID: 70176067057	Collected: 05/26/21 06:15	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.3</b>	ug/L	1.0	1		06/25/21 13:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 93		Lab ID: 70176067058		Collected: 05/26/21 06:18	Received: 06/08/21 10:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/25/21 13:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: HPMS 94		Lab ID: 70176067059	Collected: 05/26/21 06:19	Received: 06/08/21 10:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.2</b>	ug/L	1.0	1		06/25/21 13:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Sample: <b>HPMS 95</b>	Lab ID: <b>70176067060</b>	Collected: 05/26/21 06:20	Received: 06/08/21 10:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.6</b>	ug/L	1.0	1		06/25/21 13:05	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: HOLLAND PATENT MS 5/26  
Pace Project No.: 70176067

QC Batch:	215126	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70176067001, 70176067002, 70176067003, 70176067004, 70176067005, 70176067006, 70176067007, 70176067008, 70176067009, 70176067010, 70176067011, 70176067012, 70176067013, 70176067014, 70176067015, 70176067016, 70176067017, 70176067018, 70176067019, 70176067020

METHOD BLANK: 1082617 Matrix: Water

Associated Lab Samples: 70176067001, 70176067002, 70176067003, 70176067004, 70176067005, 70176067006, 70176067007, 70176067008, 70176067009, 70176067010, 70176067011, 70176067012, 70176067013, 70176067014, 70176067015, 70176067016, 70176067017, 70176067018, 70176067019, 70176067020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/25/21 11:38	

LABORATORY CONTROL SAMPLE: 1082618

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE: 1082621

Parameter	Units	70176067001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	62.2	121	70-130	

MATRIX SPIKE SAMPLE: 1082623

Parameter	Units	70176067011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	63.8	124	70-130	

SAMPLE DUPLICATE: 1082620

Parameter	Units	70176067001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.7	5	

SAMPLE DUPLICATE: 1082622

Parameter	Units	70176067011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.8	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: HOLLAND PATENT MS 5/26  
Pace Project No.: 70176067

QC Batch:	215127	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70176067021, 70176067022, 70176067023, 70176067024, 70176067025, 70176067026, 70176067027, 70176067028, 70176067029, 70176067030, 70176067031, 70176067032, 70176067033, 70176067034, 70176067035, 70176067036, 70176067037, 70176067038, 70176067039, 70176067040

METHOD BLANK: 1082624 Matrix: Water  
Associated Lab Samples: 70176067021, 70176067022, 70176067023, 70176067024, 70176067025, 70176067026, 70176067027, 70176067028, 70176067029, 70176067030, 70176067031, 70176067032, 70176067033, 70176067034, 70176067035, 70176067036, 70176067037, 70176067038, 70176067039, 70176067040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/25/21 12:07	

LABORATORY CONTROL SAMPLE: 1082625

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.4	101	85-115	

MATRIX SPIKE SAMPLE: 1082627

Parameter	Units	70176067021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.9	50	62.4	121	70-130	

MATRIX SPIKE SAMPLE: 1082629

Parameter	Units	70176067031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	65.6	130	70-130	

SAMPLE DUPLICATE: 1082626

Parameter	Units	70176067021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.9	1.9	1	

SAMPLE DUPLICATE: 1082628

Parameter	Units	70176067031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: HOLLAND PATENT MS 5/26  
Pace Project No.: 70176067

QC Batch:	215128	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70176067041, 70176067042, 70176067043, 70176067044, 70176067045, 70176067046, 70176067047, 70176067048, 70176067049, 70176067050, 70176067051, 70176067052, 70176067053, 70176067054, 70176067055, 70176067056, 70176067057, 70176067058, 70176067059, 70176067060

METHOD BLANK: 1082630 Matrix: Water  
Associated Lab Samples: 70176067041, 70176067042, 70176067043, 70176067044, 70176067045, 70176067046, 70176067047, 70176067048, 70176067049, 70176067050, 70176067051, 70176067052, 70176067053, 70176067054, 70176067055, 70176067056, 70176067057, 70176067058, 70176067059, 70176067060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/25/21 12:38	

LABORATORY CONTROL SAMPLE: 1082631

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE: 1082633

Parameter	Units	70176067041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.7	50	74.6	134	70-130	M1

MATRIX SPIKE SAMPLE: 1082635

Parameter	Units	70176067051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	64.9	128	70-130	

SAMPLE DUPLICATE: 1082632

Parameter	Units	70176067041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.7	7.7	1	

SAMPLE DUPLICATE: 1082634

Parameter	Units	70176067051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70176067001	HPMS 1	EPA 200.8	215126		
70176067002	HPMS 2	EPA 200.8	215126		
70176067003	HPMS 3	EPA 200.8	215126		
70176067004	HPMS 4	EPA 200.8	215126		
70176067005	HPMS 5	EPA 200.8	215126		
70176067006	HPMS 6	EPA 200.8	215126		
70176067007	HPMS 7	EPA 200.8	215126		
70176067008	HPMS 8	EPA 200.8	215126		
70176067009	HPMS 9	EPA 200.8	215126		
70176067010	HPMS 10	EPA 200.8	215126		
70176067011	HPMS 11	EPA 200.8	215126		
70176067012	HPMS 12	EPA 200.8	215126		
70176067013	HPMS 13	EPA 200.8	215126		
70176067014	HPMS 14	EPA 200.8	215126		
70176067015	HPMS 17	EPA 200.8	215126		
70176067016	HPMS 20	EPA 200.8	215126		
70176067017	HPMS 21	EPA 200.8	215126		
70176067018	HPMS 22	EPA 200.8	215126		
70176067019	HPMS 23	EPA 200.8	215126		
70176067020	HPMS 24	EPA 200.8	215126		
70176067021	HPMS 25	EPA 200.8	215127		
70176067022	HPMS 30	EPA 200.8	215127		
70176067023	HPMS 31	EPA 200.8	215127		
70176067024	HPMS 32	EPA 200.8	215127		
70176067025	HPMS 34	EPA 200.8	215127		
70176067026	HPMS 35	EPA 200.8	215127		
70176067027	HPMS 36	EPA 200.8	215127		
70176067028	HPMS 37	EPA 200.8	215127		
70176067029	HPMS 38	EPA 200.8	215127		
70176067030	HPMS 40	EPA 200.8	215127		
70176067031	HPMS 41	EPA 200.8	215127		
70176067032	HPMS 42	EPA 200.8	215127		
70176067033	HPMS 43	EPA 200.8	215127		
70176067034	HPMS 44	EPA 200.8	215127		
70176067035	HPMS 45	EPA 200.8	215127		
70176067036	HPMS 52	EPA 200.8	215127		
70176067037	HPMS 53	EPA 200.8	215127		
70176067038	HPMS 54	EPA 200.8	215127		
70176067039	HPMS 55	EPA 200.8	215127		
70176067040	HPMS 56	EPA 200.8	215127		
70176067041	HPMS 60	EPA 200.8	215128		
70176067042	HPMS 61	EPA 200.8	215128		
70176067043	HPMS 62	EPA 200.8	215128		
70176067044	HPMS 63	EPA 200.8	215128		
70176067045	HPMS 64	EPA 200.8	215128		
70176067046	HPMS 65	EPA 200.8	215128		
70176067047	HPMS 66	EPA 200.8	215128		
70176067048	HPMS 79	EPA 200.8	215128		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: HOLLAND PATENT MS 5/26

Pace Project No.: 70176067

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70176067049	HPMS 81	EPA 200.8	215128		
70176067050	HPMS 85	EPA 200.8	215128		
70176067051	HPMS 86	EPA 200.8	215128		
70176067052	HPMS 87	EPA 200.8	215128		
70176067053	HPMS 88	EPA 200.8	215128		
70176067054	HPMS 89	EPA 200.8	215128		
70176067055	HPMS 90	EPA 200.8	215128		
70176067056	HPMS 91	EPA 200.8	215128		
70176067057	HPMS 92	EPA 200.8	215128		
70176067058	HPMS 93	EPA 200.8	215128		
70176067059	HPMS 94	EPA 200.8	215128		
70176067060	HPMS 95	EPA 200.8	215128		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

WO#: 70176067



**CHAIN-OF-CUSTODY / Analytical Request Document**  
 The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed.

**Section A**  
 Required Client Information:  
 Company: Holland Patent Middle School  
 Address: C/O Pace  
 NY - Melville Laboratory  
 Email: www.pace.com  
 Phone: www.pace.com Fax:  
 Requested Due Date: Standard

**Section B**  
 Required Project Information:  
 Report To: Holland Patent MS  
 Copy To:  
 Purchase Order #:  
 Project Name: Holland Patent MS  
 Project #: 02214413

**Section C**  
 Invoice Information:  
 Attention: not used Patrick MS  
 Company Name: ii  
 Address:  
 Pace Quote:  
 Pace Project Manager:  
 Pace Profile #:  
 Regulatory Agency:  
 State / Location: NY

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
			START	END												
1	DW	G	05/26	0547												
2	DW	G	05/19													
3 - 2 bags	DW	G	05/11													
4 - Sprayer	DW	G	05/12													
5 - Hand wash	DW	G	05/13													
6 - L103	DW	G	06/06													
7 - ↓	DW	G	06/07													
8 - megis	DW	G	06/08													
9 - ↓	DW	G	06/09													
10 - next to log	DW	G	05/18													
11 - ↓	DW	G	05/19													
12 - ↓	DW	G	06/00													

**Requested Analysis Filtered (Y/N)**

**Analyses Test** (Y/N): Pb by EPA 200.8

**Preservatives** (Y/N):

**# OF CONTAINERS**: 1

**SAMPLE TEMP AT COLLECTION**: 1735

**RELINQUISHED BY / AFFILIATION**: Chris Putzer

**DATE**: 6/2

**TIME**: 1735

**ACCEPTED BY / AFFILIATION**: Chris Putzer

**DATE**: 6/14/05

**TIME**: 1735

**TEMP in C**: 6.9

**Received on ice (Y/N)**: N

**Custody Sealed Cooler (Y/N)**: N

**Samples Intact (Y/N)**: N

**SAMPLER NAME AND SIGNATURE**: Chris Putzer

**PRINT Name of SAMPLER**: Chris Putzer

**SIGNATURE of SAMPLER**: [Signature]

**DATE Signed**: 6/1/02





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

4415

Page: 3 of 5

### Section A Required Client Information:

Company: C/O Pace  
 Address: NY - Melville Laboratory  
 Email: www.pace.com  
 Phone:   
 Fax:   
 Requested Due Date: Standard

### Section B Required Project Information:

Report To:   
 Copy To:   
 Purchase Order #:   
 Project Name:   
 Project #: Standard

### Section C Invoice Information:

Attention:   
 Company Name: li  
 Address:   
 Pace Quote:   
 Pace Project Manager:   
 Pace Profile #: NY

Regulatory Agency:   
 State / Location: NY

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	Analyses Test Y/N	Pb by EPA 200.8	Requested Analysis Filtered (Y/N)
			START DATE TIME	END DATE TIME															
41	41	DW	05/26/05	05:19	DW/G			1											
36	36	DW	05/26/05	05:30	DW/G			1											
35	35	DW	05/26/05	05:17	DW/G			1											
34	34	DW	05/26/05	05:13	DW/G			1											
33	33	DW	05/26/05	05:19	DW/G			1											
32	32	DW	05/26/05	05:21	DW/G			1											
31	31	DW	05/26/05	05:22	DW/G			1											
30	30	DW	05/26/05	05:33	DW/G			1											
29	29	DW	06/01/05	06:41	DW/G			1											
28	28	DW	06/01/05	06:23	DW/G			1											
27	27	DW	06/01/05	06:23	DW/G			1											
26	26	DW	06/01/05	06:35	DW/G			1											

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on ice (Y/N)	Custody Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)
	Chris Putzer	6/8/05	10:50				20.9	N	N	N	N

WO#: 70176067

CHAIN-OF-CUSTODY / Analytical Request Document

PM: LS1 Due Date: 06/22/21  
CLIENT: HPCSD

Section A  
 Required Client Information:  
 Company: C/O Pace  
 Address: NY -- Melville Laboratory  
 Email: www.pace.com  
 Phone: [ ] Fax: [ ]  
 Requested Due Date: Standard

Section B  
 Required Project Information:  
 Report To:  
 Copy To:  
 Purchase Order #:  
 Project Name:  
 Project #:

Section C  
 Invoice Information:  
 Attention:  
 Company Name: II  
 Address:  
 Pace Quote:  
 Pace Project Manager:  
 Pace Profile #:

Regulatory Agency: [ ]  
 State / Location: NY

Page: [ ]

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	DATE	TIME	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	DATE	TIME	SAMPLE CONDITIONS	
			START	END													DATE
41	DW	G	05/26	06:46	05/26	06:46											
53	DW	G															
54	DW	G															
55	DW	G															
56	DW	G															
60	DW	G															
61	DW	G															
62	DW	G															
63	DW	G															
64	DW	G															
65	DW	G															
66	DW	G															
79	DW	G															

Requested Analysis Filtered (Y/N)

Analyses Test Y/N

Preservatives: H2SO4, HNO3, HCl, NaOH, Na2SO3, Methanol, Other

# OF CONTAINERS

SAMPLE TEMP AT COLLECTION

MATRIX CODE (see valid codes to left)

SAMPLE TYPE (G=GRAB C=COMP)

RELINQUISHED BY / AFFILIATION

DATE

TIME

DATE

TIME

ACCEPTED BY / AFFILIATION

DATE

TIME

DATE

TIME

SAMPLE CONDITIONS

Received on ice (Y/N)

Custody Sealed (Y/N)

Cooler (Y/N)

Samples Intact (Y/N)

TEMP in C

SAMPLER NAME AND SIGNATURE: Chris Putzer

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE Signed:





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

4415

Section C  
**Invoice Information:**  
 Attention:  
 Company Name: II  
 Address:  
 Pace Quote:  
 Pace Project Manager:  
 Pace Profile #:  
 Regulatory Agency  
 State / Location NY

Section B  
**Required Project Information:**  
 Report To:  
 Copy To:  
 Purchase Order #:  
 Project Name:  
 Project #:  
 Standard

Section A  
**Required Client Information:**  
 Company:  
 Address: C/O Pace  
 NY - Melville Laboratory  
 Email: www.pace.com  
 Phone:  
 Fax:  
 Requested Due Date: Standard

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION		# OF CONTAINERS	Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2SO3	Methanol	Other	Y/N	Analytes Test	Pd by EPA 200.8	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	START TIME			END DATE	END TIME														
YPM291	DW	DW	05/24	0643	DW G			1														
85 - Library	DW	DW	0725		DW G			1														
86 - GN near 110 Left	DW	DW	0545		DW G			1														
87 - ↓ ↓ ↓ P-15N	DW	DW	0546		DW G			1														
88 - Ass. Start Principal Bath	DW	DW	0558		DW G			1														
89 - km 107 (Downstairs faculty)	DW	DW	0555		DW G			1														
90 - Girls bathroom by 2/19/2011	DW	DW	0613		DW G			1														
91 - ↓ ↓ ↓	DW	DW	0614		DW G			1														
92 - ↓ ↓ ↓	DW	DW	0615		DW G			1														
93 - Bugs 1st floor Bldg near Elevator	DW	DW	0619		DW G			1														
94 - ↓ ↓ ↓	DW	DW	0619		DW G			1														
95 - ↓ ↓ ↓	DW	DW	0620		DW G			1														

**ADDITIONAL COMMENTS**

6/8/21 10:50 P.M. NY

*Cory...*

**ACCEPTED BY / AFFILIATION**

**DATE**

**TIME**

**DATE**

**TIME**

**SAMPLE CONDITIONS**

Received on  
 Ice (Y/N)  
 Custody (Y/N)  
 Sealed Cooler (Y/N)  
 Samples Intact (Y/N)

TEMP in C

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: Chris Putzer

SIGNATURE of SAMPLER: [Signature]

DATE Signed: [Date]



Sample Condition Upon Receipt

WO#: 70176067

Client Name: Holland Patent Middle School Project

PM: LS1 Due Date: 06/22/21  
CLIENT: HPCSD

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: 7739 2376 5544

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TH091 Correction Factor: +0.0

Cooler Temperature(°C): 20.9 Cooler Temperature Corrected(°C): 20.9

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Temperature Blank Present:  Yes  No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: MN 6/8/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: SL WT OIL		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>Htc 041002</u>		Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: KI starch test strips Lot # Residual chlorine strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide? Lead Acetate Strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/ Resolution: \_\_\_\_\_